



**I. 9.1.11 Fire-Rated Enclosures**

Chapter 9 - Facilities	Original Effective Date: August 2001
Section: 9.1 University Facilities	Date Last Reviewed: July 2021
Responsible Entity: AVP for Facilities, Safety, and Risk Management	Date Last Revised: July 2021

**II. Purpose**

To establish prior approval requirements for any work to be performed in fire-rated enclosures.

**III. Scope**

This policy applies to external contractors, Facilities Management, Information Management Services (IMS), repair personnel/vendors, their supervisors (including outside contractors), and other individuals performing wall or floor Penetration work in Fire-Rated Enclosures.

**IV. Policy**

The fire-rated areas within UT Health San Antonio facilities provide services critical to the strategic mission of UT Health San Antonio.

- A. Any action that may significantly affect the integrity of a Fire-Rated Enclosure must be reviewed by Facilities Management personnel prior to beginning any work.
- B. All existing Penetrations into Fire-Rated Enclosures must be resealed or corrected using accepted procedures and methods in accordance with the sketches and specifications available from the Design and Engineering division of Facilities Management.
- C. New Penetrations into fire-rated enclosures must be reviewed by Facilities Management prior to and following the penetration work.
- D. The supervisor in the requesting department is required to verify compliance with this policy prior to beginning a project within a Fire-Rated Enclosure. The supervisor is to consult with the Design and Engineering division or the Director/Assistant Director of Construction and Project Management (or their designated representative) in Facilities Management to ensure work is completed as required by this policy.

## 9.1.11 Fire-Rated Enclosures

### V. Definitions

When used in this document, the following words have the meaning set forth below unless a different meaning is required by context.

Fire-Rated Enclosure - refers to a structure with a fire resistance rating approved by the authority having jurisdiction that is designed and maintained to prevent the passage of smoke and fire. Examples include stairs, mechanical rooms, elevator hoistways, utility shafts, corridor walls, and return air plenum.

Penetration - an opening in a fire-rated enclosure that includes penetration of pipes, conduits, ducts, cables, pneumatic tubes, and similar building services.

### VI. Related References

*There are no related documents associated with this Policy.*

### VII. Review and Approval History

The approving authority of this policy is the University Executive Committee.

Effective Date	Action Taken	Approved By	Approved Date
08/2001	Policy Origination		
06/2017	Policy Revision		
07/2021	Policy Revision/discretionary edits		